



**EA MLA Signatory**  
**Český institut pro akreditaci, o.p.s.**  
(Czech Accreditation Institute)  
**Hájkova 2747/22, Žižkov, 130 00 Praha 3**

issues

according to section 16 of Act No. 22/1997 Coll., on technical requirements for products and on changes and amendments to some Acts, as amended

# **CERTIFICATE OF ACCREDITATION**

**No. 396/2025**

**HEATEST, s.r.o.**  
**with registered office č.p. 84, 276 01 Býkev**  
**Company Registration No. 27390951**

**for the Testing Laboratory No. 1477**  
**HEATEST, s.r.o.**

**Scope of accreditation:**

Testing of thermal-technical properties of radiators and convectors and assessment of their characteristics to the extent as specified in the appendix to this Certificate.

This Certificate of Accreditation is a proof of accreditation issued on the basis of assessment of fulfillment of the accreditation criteria in accordance with

**ČSN EN ISO/IEC 17025:2018**

In its activities performed within the scope and for the period of validity of this Certificate, the abovementioned Accredited Body is entitled to refer to this Certificate, provided that the accreditation is not suspended and the Accredited Body meets the specified accreditation requirements in accordance with the relevant regulations applicable to the activity of an accredited conformity assessment body.

This Certificate of Accreditation replaces, to the full extent, Certificate No.: 107/2024 of 06/03/2024, and/or any administrative acts building upon it.

**The Certificate of Accreditation is valid until: 06/03/2029**

Prague: 30/07/2025



Signed in the Czech original:  
Jan Velíšek on 30/07/2025

**Jan Velíšek**  
Director of the Department  
of Testing and Calibration Laboratories  
Czech Accreditation Institute

This translation of the Czech original has been issued by: Eliška Frycová



**The Appendix is an integral part of  
Certificate of Accreditation No: 396/2025 of 30/07/2025**

**Accredited entity according to ČSN EN ISO/IEC 17025:2018:**

**HEATEST, s.r.o.**  
CAB number 1477, HEATEST, s.r.o.  
č.p. 84, 276 01 Býkev

**Tests:**

Ordinal number <sup>1</sup>	Test procedure / method name	Test procedure / method identification <sup>2</sup>	Tested subject	Degrees of freedom <sup>3</sup>
1	Test of thermal output	ČSN EN 442-2; GOST R 53583	Radiators and convectors fed with water	-
2	Test of thermal output	ČSN EN 16430-2; ČSN EN 1397, cl. 7	Radiators and convectors fed with water with fans or ventilation, trench convectors, heat exchangers, hydronic room fan coil units	-
3	Determination of pressure drop	ČSN EN 442-2, Annex B	Radiators and convectors fed with water, heat exchangers	-
4	Test of cooling capacity	ČSN EN 16430-3; ČSN EN 1397, cl. 7	Fan assisted radiators, convectors and trench convectors, ventilation radiators and trench convectors	-
5	Test of cooling capacity	ČSN EN 14240	Chilled ceilings	-
6	Test of cooling capacity	ČSN EN 14518	Passive chilled beams	-
7	Test of cooling capacity	ČSN EN 15116	Active chilled beams	-
8	Reserved			
9	Pressure tightness	ČSN EN 442-1 ed.2, cl. 5.4; ČSN EN 16430-1, cl. 5.3; GOST 31311, cl. 8.4;	Radiators, convectors, trench convectors fed with water	-
10	Resistance to pressure	ČSN EN 442-1 ed.2, cl. 5.6; ČSN EN 16430-1, cl. 5.4; ČSN EN 14037-1 ed. 2, cl. 5.8; GOST 31311, cl. 8.4	Radiators and convectors fed with water including trench convectors, free hanging heating and cooling surfaces, ceiling radiant panels	-
11	Test of static strength	GOST 31311, cl. 8.5	Radiators and convectors fed with water including trench convectors	-

**The Appendix is an integral part of  
Certificate of Accreditation No: 396/2025 of 30/07/2025**

**Accredited entity according to ČSN EN ISO/IEC 17025:2018:**

**HEATEST, s.r.o.**  
CAB number 1477, HEATEST, s.r.o.  
č.p. 84, 276 01 Býkev

Ordinal number <sup>1</sup>	Test procedure / method name	Test procedure / method identification <sup>2</sup>	Tested subject	Degrees of freedom <sup>3</sup>
12	Determination of coating resistance – cross-cut test	ČSN EN ISO 2409	Coatings, varnishes, coating systems	-
13	Determination of thickness with a magnetic-induction device	ČSN EN ISO 2808, cl. 5.5.6, cl. 7.B.2	Coatings, varnishes, coating systems	-
14	Determination of thickness using a device for eddy current measurements	ČSN EN ISO 2808, cl. 5.5.7, cl. 7C	Coatings, varnishes, coating systems	-

<sup>1</sup> asterisk at the ordinal number identifies the tests, which the laboratory is qualified to carry out outside the permanent laboratory premises

<sup>2</sup> if the document identifying the test procedure is dated, only these specific procedures are used. If the document identifying the test procedure is not dated, the latest valid edition of the specified procedure is used (including any changes)

<sup>3</sup> the laboratory does not apply a flexible approach to the scope of accreditation

**Accreditation for purposes of authorization/notification:**

Ordinal number	Product / Product group name	Conformity assessment procedure / module / AVCP system	Basic requirements / harmonized technical specifications: product specifications / characteristics / technical standards <sup>1</sup>
1	<b>Construction products according to the Regulation (EU) No. 305/2011</b>		
1.1	<b>Space heating appliances</b>		
1.1.1	Space heating appliances without internal energy source (for use in buildings) (according to Annex III. CD 99/471/EC as amended by 2001/596/EC)	Regulation (EU) No. 305/2011 system 3	ČSN EN 442-1, ed.2; EN 442-1

<sup>1</sup> for dated documents identifying essential requirements / harmonised technical specifications: product specifications / features / technical standards, only the editions cited are used; for undated documents, the latest edition of the referenced document (including any amendments) is used.

*"This document is an appendix to the certificate of accreditation. In case of any discrepancies between the English and Czech versions, the Czech version shall prevail, both for the certificate appendix and the certificate itself."*